Skip to main content

GOV.UK

Energy Performance of Buildings Register

beta This is a new service – your feedback will help us to improve it.

Back

Energy performance certificate (EPC)

Certificate contents

Rules on letting this property

Energy performance rating for this property

Breakdown of property's energy performance

Environmental impact of this property

How to improve this property's energy performance

Estimated energy use and potential savings

Contacting the assessor and accreditation scheme

Energy rating

E

Flat 5 Glebe House
Widcombe Hill
BATH
BA2 6AA

Valid until 23 February 2025

Certificate number **2748-6072-7272-3035-5994**

Print this certificate

Property type
Top-floor flat
Total floor area
74 square metres

Rules on letting this property


Properties can be rented if they have an energy rating from A to E.

If the property is rated F or G, it cannot be let, unless an exemption has been registered. You can read guidance for landlords on the regulations and exemptions.

Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be C.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher this number, the lower your carbon dioxide (CO2) emissions are likely to be.

The average energy rating and score for a property in England and Wales are D (60).

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says 'assumed', it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 300 mm loft insulation	Very good
Window	Fully double glazed	Average
Main heating	Electric storage heaters	Average
Main heating control	Manual charge control	Poor
Hot water	Electric immersion, off-peak	Very poor
Lighting	Low energy lighting in 57% of fixed outlets	Good
Floor	(another dwelling below)	N/A
Secondary heating	Room heaters, electric	N/A

Primary energy use

The primary energy use for this property per year is 502 kilowatt hours per square metre (kWh/m2).

▶ What is primary energy use?

Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO2). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO2 emissions.

An average household produces
6 tonnes of CO2

This property produces
6.3 tonnes of CO2

This property's potential production
3.5 tonnes of CO2

By making the recommended changes, you could reduce this property's CO2 emissions by 2.8 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

How to improve this property's energy performance

Potential energy rating

C

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (49) to C (75).

▶ What is an energy rating?

Recommendation 1: Cavity wall insulation

Cavity wall insulation

Typical installation cost £500 - £1,500

Typical yearly saving £369

Potential rating after carrying out recommendation 1 65 | D

Recommendation 2: Low energy lighting

Low energy lighting

Typical installation cost £15

Typical yearly saving £18

Potential rating after carrying out recommendations 1 and 2 66 | D

Recommendation 3: High heat retention storage heaters

High heat retention storage heaters

Typical installation cost £1,600 - £2,400

Typical yearly saving £205

Potential rating after carrying out recommendations 1 to 3 75 | C

Paying for energy improvements

Find energy grants and ways to save energy in your home.

Estimated energy use and potential savings

Estimated yearly energy cost for this property
£1132
Potential saving
£592

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in how to improve this property's energy performance.

For advice on how to reduce your energy bills visit Simple Energy Advice.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Space heating
9777.0 kWh per year
Water heating
1865.0 kWh per year

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved
Cavity wall insulation	4531 kWh per year

You might be able to receive Renewable Heat Incentive payments. This will help to reduce carbon emissions by replacing your existing heating system with one that generates renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name
Neil Tyrie
Telephone
(0)7875 746 880
Email
neil.tyrie@hotmail.co.uk

Accreditation scheme contact details

Accreditation scheme
Quidos Limited
Assessor ID
QUID200944
Telephone
01225 667 570
Email
info@quidos.co.uk

Assessment details

Assessor's declaration
No related party
Date of assessment
24 February 2015
Date of certificate
24 February 2015
Type of assessment
- RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk, or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.

Support links

- Accessibility statement
- Cookies on our service

OGL All content is available under the Open Government Licence v3.0, except where otherwise stated
© Crown copyright